

TECHNICKY SKUSOBNY USTAV PIESTANY, s.p. TECHNICKY SKUSOBNY USTAV PIESTA
Krajinska cesta 2929/9
921 01 Piešťany, Slovak Republic Notified body No. 1299



CERTIFICATE OF CONSTANCY OF PERFORMANCE

1299 - CPR - 0200

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Hose system with lay-flat hose d = 52 mm

Type: cabinet 500x500x150mm without reel cabinet 650x550x200 mm with reel cabinet 650x550x200mm without reel

cabinet 800x650x200mm with room for fire extinguisher and with reel

Hose bore: d = 52 mm

Minimum K - coefficient for 1a) + 2a) + 3a):

 iet: 72 (l/min.MPa^{-1/2}) - spray: 104 (I/min.MPa^{-1/2})

Minimum flow rate: (MPa/l.min⁻¹) 0.4/145

Minimum K - coefficient for 1b) + 2b) + 3b):

- jet: 72 (l/min.MPa^{-1/2}) - spray: 103 (l/min.MPa^{-1/2})

Minimum flow rate: (MPa/l.min⁻¹) 0,4/144

(specification components is stated on the back page:

placed on the market under the name of

SC FIRE STING SRL PLOIESTI, SOS. VESTULUI, NR.16, BL. 103, AP. 42, JUD. PRAHOVA, ROMANIA

and produced in the manufacturing plant

SC FIRE STING SRL SOSEAUA BRAILEI 1A, 120118 BUZAU, ROMANIA

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 671-2:2012

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 30.05.2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The certificate shall be supported through annual continuous surveillance and reissued after each surveillance. This certificate shall be reissued not later than 29.05.2025. A new issue of the certificate is conditioned by positive results of the surveillance.

Piešťany 24.05.2024

Issue:

Dusan HANKO on behalf of TSU Piešťany, š.p. Olified Body Notified body 1299

Components specification:

- 1. Inlet stop valve:
 - a) 2" fire hydrant, dimension: DN 50, PN 16, brass, manufacturer / supplier: Zyfire, China
 - b) 2" fire hydrant, dimension: DN 50, PN 16, brass and aluminium, manufacturer / supplier: Bodtech, Poland
- 2. Lay-flat hose:
 - a) dimension 52 mm, manufacturer / supplier: Bodtech Poland
 - b) dimension 52 mm, manufacturer / supplier: Zyfire, China
- 3. Nozzle combined:
 - a) Shut-off nozzle, given equiv. diameter: 13, manufacturer / supplier: Supron, Poland
 - b) Shut-off nozzle, given equiv. diameter: 12, manufacturer / supplier: Zyfire, China
- 4. Cabinet and reel: manufacturer or supplier: SC FIRE STING SRL, Romania

